

ORDINANCE NO. 10 -00

TOWNSHIP OF MIDDLESEX
CUMBERLAND COUNTY, PENNSYLVANIA

AN ORDINANCE OF THE BOARD OF TOWNSHIP SUPERVISORS
IN AND FOR MIDDLESEX TOWNSHIP, CUMBERLAND COUNTY,
PENNSYLVANIA AMENDING ORDINANCE NO. 1-89 ENACTED
MARCH 1, 1989 AND THE "MIDDLESEX TOWNSHIP PRETREATMENT
PROGRAM, MARCH 1989" (AS SUBSEQUENTLY AMENDED BY
ORDINANCES NO. 10-91 AND 7-93) TO REVISE DISCHARGE
LIMITATIONS AND TO REPEAL ORDINANCE NO. 9-00

NOW THEREFORE, it is hereby ENACTED AND ORDAINED by the Board of
Township Supervisors in and for the Township of Middlesex, as follows:

SECTION 1: PREAMBLE AND BACKGROUND.

On March 1, 1989 this Board of Township Supervisors enacted Ordinance No. 1-89
which establishes a wastewater pretreatment program known as "Middlesex Township
Pretreatment Program, March 1989". Said program was subsequently amended by Ordinance
No. 10-91 and Ordinance No. 7-93. Because of changes permitted by the Environmental
Protection Agency ("EPA") in local wastewater discharge limitations, it was necessary to modify
and amend the Pretreatment Program with respect to such limitations. Ordinance No. 9-00 was
enacted for such purpose; however, further modifications are necessary to comply with EPA
requirements.

SECTION 2: AMENDMENT TO PRETREATMENT PROGRAM.

The Pretreatment Program is hereby amended in the following respect:

The Wastewater Discharge Limitations in subsection 8.2 of Section 8 on page 31 of the
Pretreatment Program are hereby repealed.

New subsection 8.2 of Section 8 on page 31 of the Pretreatment Program shall be as follows:

8.2 Wastewater Discharge Limitations

<u>Parameter</u>	<u>Monthly Average</u>
Temperature	60° Celsius
pH	6.0 – 9.5 Standard Units
Flow	Report for each point of discharge

<u>Parameter</u>	<u>Monthly Average (milligrams per liter)</u>
Fats, Oils and Grease*	286 MG/L

<u>Parameter</u>	<u>Monthly Average Mass (pounds per day unless otherwise noted _____)</u>
Arsenic	0.80
Cadmium	0.75
Chromium	8.3
Copper	2.6
Lead	2.9
Mercury	0.012
Molybdenum	1.5
Nickel	8.1
Selenium	1.9
Silver	5.5
Zinc	3.2
Cyanide	3.4
BOD-5*	7025
Total Suspended Solids*	6186
Phosphorus as P*	2063
Ammonia – Nitrogen*	564

TTO (Total Toxic Organics) Report Results – Federal Categorical Standards Apply

*Users found discharging these Pollutants in excess of the above maximum limits shall, in addition to any other remedies provided under this Program, be assessed a surcharge for the removal thereof in accordance with the formula as provided in Section 4I hereinabove.

Individual significant industrial user permit limits will be developed in conjunction with flow limits for each significant industrial user. This will ensure that the allowable mass discharge for each user when combined with the other users' pollutant contributions will not exceed the local limits detailed above. Industrial discharge permit limits will be expressed as concentrations in specific significant industrial users wastewater discharge permits to simplify compliance monitoring.

SECTION 3: VALIDITY OF PRIOR ORDINANCES.

In all other respects, Ordinance No. 1-89, Ordinance 10-91 and Ordinance 7-93 shall remain as heretofore enacted and amended. Ordinance No. 9-00 is hereby repealed.

SECTION 4: SEVERABILITY.

If any provision, section, sentence, clause or portion of this ordinance shall be held invalid or unconstitutional by any court of competent jurisdiction, such invalidity or unconstitutionality shall not affect any other provision, section, sentence, clause or portion of this ordinance which shall continue and remain in full force and effect.

SECTION 5: REPEAL OF PRIOR INCONSISTENT ORDINANCES.

All prior ordinances or parts of ordinances inconsistent herewith are hereby repealed.

SECTION 6: EFFECTIVE DATE.

This ordinance shall become effective in accordance with existing law.

DULY ENACTED AND ORDAINED this 6 day of December ,
2000 by the said Board of Township Supervisors in lawful session duly assembled.

TOWNSHIP OF MIDDLESEX

By Robert M. Eppley
Chairman, Board of Township Supervisors

ATTEST:

Mary S. Juste
Township Secretary

(Township Seal)